

TABLE 1
Summary of Analytical Results for Caulk Samples -- June 2010
P.S. 178X
Bronx, New York

Analysis	Analyte	Sample ID:	178-103-CK- PRE-1	178-103-CK- PRE-2	178-103-CK- PRE-3	178-104-CK- PRE-1	178-137-CK- PRE-1	178-138-CK- PRE-1	178-139-CK- PRE-2	178-139-CK- PRE-3	178-140-CK- PRE-1	178-143-CK- PRE-2
		Sample Description:	Door Window Glaze	Display Case Caulk	Display Case Glaze	Sink/Urinal/T oilet Caulk	Sink/Toilet Caulk	Sink/Urinal/T oilet Caulk	Window Frame Caulk	Window Sill Caulk	Sink Caulk	Window Frame Caulk
		Sample Location:	Lobby 103	Lobby 103	Lobby 103	Room 104 BR	Room 137 BR	Room 138 BR	Room 139	Room 139	Room 140 BR	Room 143
		Sample Date:	6/16/2010	6/16/2010	6/16/2010	6/24/2010	6/24/2010	6/24/2010	6/12/2010	6/12/2010	6/24/2010	6/12/2010
Action Level*												
PCBs (mg/kg)	Aroclor 1016	N/A	0.331 U	16.2 U	1.23 U	0.333 U	0.334 U	0.331 U	32.0 U	0.645 U	0.332 U	0.982 U
	Aroclor 1221	N/A	0.331 U	16.2 U	1.23 U	0.333 U	0.334 U	0.331 U	32.0 U	0.645 U	0.332 U	0.982 U
	Aroclor 1232	N/A	0.331 U	16.2 U	1.23 U	0.333 U	0.334 U	0.331 U	32.0 U	0.645 U	0.332 U	0.982 U
	Aroclor 1242	N/A	0.331 U	16.2 U	1.23 U	0.333 U	0.334 U	0.331 U	32.0 U	0.645 U	0.332 U	0.982 U
	Aroclor 1248	N/A	0.331 U	16.2 U	1.23 U	0.333 U	0.334 U	0.331 U	32.0 U	0.645 U	0.332 U	0.982 U
	Aroclor 1254	N/A	2.19 J	114 J	61.2 J	0.333 U	0.334 U	0.331 U	32.0 U	11.0 J	0.332 U	21.7 J
	Aroclor 1260	N/A	0.331 U	16.2 U	1.23 U	0.333 U	0.334 U	0.331 U	1,120 J	5.55 J	0.332 U	7.66 J
	Total PCBs	50	2.19 J	114 J	61.2 J	0.333 U	0.334 U	0.331 U	1,120 J	16.55 J	0.332 U	29.36 J

Notes:

mg/kg - milligrams per kilogram or parts per million (ppm).

J - Estimated value.

N/A - Not applicable.

U - Compound was not detected at specified quantitation limit.

UJ - Estimated non-detect.

Values in **Bold** indicate the compound was detected.

Values shown in Bold and shaded type exceed the listed Action Level.

PCBs - Polychlorinated Biphenyls.

* - EPA definition of PCB Caulk pertains to any caulk sample containing >= 50 mg/kg total PCBs.

Data validation for all samples completed.

TABLE 1
Summary of Analytical Results for Caulk Samples -- June 2010
P.S. 178X
Bronx, New York

Analysis	Analyte	Sample ID:	178-143-CK- PRE-3	178-143-CK- PRE-4	178-144-CK- PRE-1	178-153-CK- PRE-1	178-170-CK- PRE-1	178-171-CK- PRE-1	178-172-CK- PRE-1	178-172-CK- PRE-2	178-172-CK- PRE-3	178-172-CK- PRE-4	
			Sample Description:	Window Sill Caulk	Sink Countertop Caulk	Sink Caulk	Sink/Toilet/ Mirror Caulk	Sink/Urinal/ oilet Caulk	Toilet/Sink Caulk	Single Panel Door Window	Single Panel Door Window	Plexiglass Window Glaze to Kitchen	Glass Window Glaze to Kitchen
			Sample Location:	Room 143	Room 143	Room 144 BR	Room 153 BR	Room 170 BR	Room 171 BR	Cafeteria	Cafeteria	Cafeteria	Cafeteria
			Sample Date:	6/12/2010	6/12/2010	6/24/2010	6/24/2010	6/24/2010	6/12/2010	6/12/2010	6/12/2010	6/12/2010	6/12/2010
		Action Level*											
PCBs (mg/kg)	Aroclor 1016	N/A	1.33 U	0.332 U	0.331 U	0.330 U	0.333 U	0.423 U	0.333 U	0.333 U	0.315 U	0.314 U	
	Aroclor 1221	N/A	1.33 U	0.332 U	0.331 U	0.330 U	0.333 U	0.423 U	0.333 U	0.333 U	0.315 U	0.314 U	
	Aroclor 1232	N/A	1.33 U	0.332 U	0.331 U	0.330 U	0.333 U	0.423 U	0.333 U	0.333 U	0.315 U	0.314 U	
	Aroclor 1242	N/A	1.33 U	0.332 U	0.331 U	0.330 U	0.333 U	0.423 U	0.333 U	0.333 U	0.315 U	0.314 U	
	Aroclor 1248	N/A	1.33 U	0.332 U	0.331 U	0.330 U	0.333 U	0.423 U	0.333 U	0.333 U	0.315 U	0.314 U	
	Aroclor 1254	N/A	22.8 J	0.332 U	0.331 U	0.330 U	1.78 J	0.533 J	6.09 J	0.530 J	0.841 J	0.690 J	
	Aroclor 1260	N/A	7.78 J	0.332 U	0.331 U	0.330 U	0.333 U	0.423 U	0.333 U	0.333 U	0.315 U	0.314 U	
	Total PCBs	50	30.58 J	0.332 U	0.331 U	0.330 U	1.78 J	0.533 J	6.09 J	0.530 J	0.841 J	0.690 J	

Notes:

mg/kg - milligrams per kilogram or parts per million (ppm).

J - Estimated value.

N/A - Not applicable.

U - Compound was not detected at specified quantitation limit.

UJ - Estimated non-detect.

Values in **Bold** indicate the compound was detected.

Values shown in Bold and shaded type exceed the listed Action Level.

PCBs - Polychlorinated Biphenyls.

* - EPA definition of PCB Caulk pertains to any caulk sample containing >= 50 mg/kg total PCBs.

Data validation for all samples completed.

TABLE 1
Summary of Analytical Results for Caulk Samples -- June 2010
P.S. 178X
Bronx, New York

Analysis	Analyte	Sample ID:	178-172-CK-PRE-5	178-172-CK-PRE-7	178-175/178-CK-PRE-1	178-179/182-CK-PRE-1	178-182-CK-PRE-2	178-182-CK-PRE-3	178-207-CK-PRE-1	178-207-CK-PRE-2	178-208B-CK-PRE-1	178-208G-CK-PRE-1
		Sample Description:	Caulk Between Wood Panel and Soffit	Caulk Behind Drinking Fountain	Sink + Mirror Caulk	Sink Caulk	Window Frame Caulk	Window Sill Caulk	Window Sill Caulk	Window Frame Caulk	Toilet/Urinal/Sink Caulk	Toilet/Sink Caulk
		Sample Location:	Cafeteria	Cafeteria	Room 175/178 BR	Room 179/182 BR	Room 182	Room 182	Room 207	Room 207	Room 208B BR	Room 208G BR
		Sample Date:	6/12/2010	6/12/2010	6/24/2010	6/24/2010	6/12/2010	6/12/2010	6/12/2010	6/12/2010	6/24/2010	6/24/2010
Action Level*												
PCBs (mg/kg)	Aroclor 1016	N/A	0.324 U	1.50 U	0.331 U	0.333 U	12.4 U	1,320 U	0.651 U	0.664 U	0.331 U	0.334 UJ
	Aroclor 1221	N/A	0.324 U	1.50 U	0.331 U	0.333 U	12.4 U	1,320 U	0.651 U	0.664 U	0.331 U	0.334 UJ
	Aroclor 1232	N/A	0.324 U	1.50 U	0.331 U	0.333 U	12.4 U	1,320 U	0.651 U	0.664 U	0.331 U	0.334 UJ
	Aroclor 1242	N/A	0.324 U	1.50 U	0.331 U	0.333 U	12.4 U	1,320 U	0.651 U	0.664 U	0.331 U	0.334 UJ
	Aroclor 1248	N/A	0.324 U	1.50 U	0.331 U	0.333 U	12.4 U	1,320 U	0.651 U	0.664 U	0.331 U	0.334 UJ
	Aroclor 1254	N/A	1.47 J	1.50 U	0.331 U	0.333 U	12.4 U	1,320 U	0.651 U	15.3 J	0.331 U	0.334 UJ
	Aroclor 1260	N/A	0.324 U	1.50 U	0.331 U	0.333 U	261 J	23,700 J	6.78 J	5.39 J	0.331 U	0.334 UJ
	Total PCBs	50	1.47 J	1.50 U	0.331 U	0.333 U	261 J	23,700 J	6.78 J	20.69 J	0.331 U	0.334 UJ

Notes:

mg/kg - milligrams per kilogram or parts per million (ppm).

J - Estimated value.

N/A - Not applicable.

U - Compound was not detected at specified quantitation limit.

UJ - Estimated non-detect.

Values in **Bold** indicate the compound was detected.

Values shown in Bold and shaded type exceed the listed Action Level.

PCBs - Polychlorinated Biphenyls.

* - EPA definition of PCB Caulk pertains to any caulk sample containing >= 50 mg/kg total PCBs.

Data validation for all samples completed.

TABLE 1
Summary of Analytical Results for Caulk Samples -- June 2010
P.S. 178X
Bronx, New York

Analysis	Analyte	Sample ID:	178-223-CK- PRE-1	178-223-CK- PRE-2	178-231-CK- PRE-1	178-232-CK- PRE-1	178-239-CK- PRE-1	178-239-CK- PRE-2	178-239-CK- PRE-4	178-246-CK- PRE-1	178-247-CK- PRE-1	178-258-CK- PRE-1		
			Sample Description:	Window Sill Caulk	Window Frame Caulk	Toilet/Sink Caulk	Toilet/Urinal/ Sink Caulk	Window Frame Caulk	Window Sill Caulk	Partition Window Glaze	Sink/Toilet Caulk	Toilet/Urinal/ Sink Caulk	Window Sill Caulk	
			Sample Location:	Room 223	Room 223	Room 231 BR	Room 232 BR	Room 239	Room 239	Room 239	Room 239	Room 246 BR	Room 247 BR	Room 258
			Sample Date:	6/12/2010	6/12/2010	6/24/2010	6/24/2010	6/16/2010	6/16/2010	6/16/2010	6/16/2010	6/24/2010	6/24/2010	6/12/2010
		Action Level*												
PCBs (mg/kg)	Aroclor 1016	N/A	1.94 U	13.3 U	0.332 UJ	0.331 U	3,230 U	0.324 U	0.332 U	0.332 U	0.330 U	0.328 U		
	Aroclor 1221	N/A	1.94 U	13.3 U	0.332 UJ	0.331 U	3,230 U	0.324 U	0.332 U	0.332 U	0.330 U	0.328 U		
	Aroclor 1232	N/A	1.94 U	13.3 U	0.332 UJ	0.331 U	3,230 U	0.324 U	0.332 U	0.332 U	0.330 U	0.328 U		
	Aroclor 1242	N/A	1.94 U	13.3 U	0.332 UJ	0.331 U	3,230 U	0.324 U	0.332 U	0.332 U	0.330 U	0.328 U		
	Aroclor 1248	N/A	1.94 U	13.3 U	0.332 UJ	0.331 U	3,230 U	0.324 U	0.332 U	0.332 U	0.330 U	0.328 U		
	Aroclor 1254	N/A	1.94 U	13.3 U	0.332 UJ	0.331 U	3,230 U	6.12 J	0.449 J	0.332 U	0.330 U	8.36 J		
	Aroclor 1260	N/A	7.39 J	255 J	0.332 UJ	0.331 U	85,100 J	4.63 J	0.332 U	0.332 U	0.330 U	4.29 J		
	Total PCBs	50	7.39 J	255 J	0.332 UJ	0.331 U	85,100 J	10.75 J	0.449 J	0.332 U	0.330 U	12.65 J		

Notes:

mg/kg - milligrams per kilogram or parts per million (ppm).

J - Estimated value.

N/A - Not applicable.

U - Compound was not detected at specified quantitation limit.

UJ - Estimated non-detect.

Values in **Bold** indicate the compound was detected.

Values shown in Bold and shaded type exceed the listed Action Level.

PCBs - Polychlorinated Biphenyls.

* - EPA definition of PCB Caulk pertains to any caulk sample containing >= 50 mg/kg total PCBs.

Data validation for all samples completed.

TABLE 1
Summary of Analytical Results for Caulk Samples -- June 2010
P.S. 178X
Bronx, New York

Analysis	Analyte	Sample ID:	178-258-CK- PRE-3	178-258-CK- PRE-4	178-259-CK- PRE-1	178-260-CK- PRE-1	178-263-CK- PRE-1	178-264-CK- PRE-1	178-264-CK- PRE-2	178-264-CK- PRE-3	178-304-CK- PRE-1	178-304-CK- PRE-2	
			Window Frame Caulk	AC Caulk	Sink/Urinal/ Toilet Caulk	Toilet/Sink Caulk	Partition Window Glaze	Sink Caulk	Door Window Glaze	Sink Caulk	Window Sill Caulk	Window Frame Caulk	
			Sample Location:	Room 258	Room 258	Room 259 BR	Room 260 BR	Room 263	Room 264 Gym 2	Room 264 Gym 2	Room 264 Gym 2	Room 304	Room 304
			Sample Date:	6/12/2010	6/12/2010	6/24/2010	6/24/2010	6/12/2010	6/16/2010	6/16/2010	6/16/2010	6/12/2010	6/12/2010
		Action Level*											
PCBs (mg/kg)	Aroclor 1016	N/A	3,290 U	231 U	0.332 U	0.332 UJ	0.325 U	0.323 U	0.329 U	0.387 U	1.99 U	9.88 U	
	Aroclor 1221	N/A	3,290 U	231 U	0.332 U	0.332 UJ	0.325 U	0.323 U	0.329 U	0.387 U	1.99 U	9.88 U	
	Aroclor 1232	N/A	3,290 U	231 U	0.332 U	0.332 UJ	0.325 U	0.323 U	0.329 U	0.387 U	1.99 U	9.88 U	
	Aroclor 1242	N/A	3,290 U	231 U	0.332 U	0.332 UJ	0.325 U	0.323 U	0.329 U	0.387 U	1.99 U	9.88 U	
	Aroclor 1248	N/A	3,290 U	231 U	0.332 U	0.332 UJ	0.325 U	0.323 U	0.684 J	0.387 U	1.99 U	9.88 U	
	Aroclor 1254	N/A	3,290 U	231 U	0.332 U	0.332 UJ	5.78 J	0.323 U	2.43 J	0.476 J	21.2 J	9.88 U	
	Aroclor 1260	N/A	90,700 J	6,000 J	0.332 U	0.332 UJ	0.325 U	0.323 U	0.329 U	0.387 U	26.8 J	161 J	
	Total PCBs	50	90,700 J	6,000 J	0.332 U	0.332 UJ	5.78 J	0.323 U	3.114 J	0.476 J	48.0 J	161 J	

Notes:

mg/kg - milligrams per kilogram or parts per million (ppm).

J - Estimated value.

N/A - Not applicable.

U - Compound was not detected at specified quantitation limit.

UJ - Estimated non-detect.

Values in **Bold** indicate the compound was detected.

Values shown in Bold and shaded type exceed the listed Action Level.

PCBs - Polychlorinated Biphenyls.

* - EPA definition of PCB Caulk pertains to any caulk sample containing >= 50 mg/kg total PCBs.

Data validation for all samples completed.

TABLE 1
Summary of Analytical Results for Caulk Samples -- June 2010
P.S. 178X
Bronx, New York

Analysis	Analyte	Sample ID:	178-308-CK- PRE-1	178-309-CK- PRE-1	178-322A- CK-PRE-1	178-322A- CK-PRE-2	178-331-CK- PRE-1	178-332-CK- PRE-1	178-337A- CK-PRE-1	178-337A- CK-PRE-2	178-346-CK- PRE-1	178-347-CK- PRE-1
		Sample Description:	Sink/Urinal/ oilet Caulk	Sink/Toilet Caulk	Window Sill Caulk	Window Frame Caulk	Sink/Toilet Caulk	Toilet/Urinal/ Sink Caulk	Window Frame Caulk	Window Sill Caulk	Sink/Toilet Caulk	Toilet/Urinal/ Sink Caulk
		Sample Location:	Room 308 BR	Room 309 BR	Room 322A	Room 322A	Room 331 BR	Room 332 BR	Room 337A	Room 337A	Room 346 BR	Room 347 BR
		Sample Date:	6/24/2010	6/24/2010	6/12/2010	6/12/2010	6/24/2010	6/24/2010	6/12/2010	6/12/2010	6/24/2010	6/24/2010
		Action Level*										
PCBs (mg/kg)		N/A	0.333 UJ	0.331 UJ	1.66 U	9.91 U	0.524 U	0.332 U	6.58 U	0.985 U	0.441 UJ	0.332 U
	Aroclor 1016	N/A	0.333 UJ	0.331 UJ	1.66 U	9.91 U	0.524 U	0.332 U	6.58 U	0.985 U	0.441 UJ	0.332 U
	Aroclor 1221	N/A	0.333 UJ	0.331 UJ	1.66 U	9.91 U	0.524 U	0.332 U	6.58 U	0.985 U	0.441 UJ	0.332 U
	Aroclor 1232	N/A	0.333 UJ	0.331 UJ	1.66 U	9.91 U	0.524 U	0.332 U	6.58 U	0.985 U	0.441 UJ	0.332 U
	Aroclor 1242	N/A	0.333 UJ	0.331 UJ	1.66 U	9.91 U	0.524 U	0.332 U	6.58 U	0.985 U	0.441 UJ	0.332 U
	Aroclor 1248	N/A	0.333 UJ	0.331 UJ	1.66 U	9.91 U	0.524 U	0.332 U	6.58 U	0.985 U	0.441 UJ	0.332 U
	Aroclor 1254	N/A	0.333 UJ	0.331 UJ	33.5 J	9.91 U	0.524 U	0.332 U	6.58 U	14.3 J	0.441 UJ	0.332 U
	Aroclor 1260	N/A	0.333 UJ	0.331 UJ	1.66 U	249 J	0.524 U	0.332 U	135 J	4.19 J	0.441 UJ	0.332 U
	Total PCBs	50	0.333 UJ	0.331 UJ	33.5 J	249 J	0.524 U	0.332 U	135 J	18.49 J	0.441 UJ	0.332 U

Notes:

mg/kg - milligrams per kilogram or parts per million (ppm).

J - Estimated value.

N/A - Not applicable.

U - Compound was not detected at specified quantitation limit.

UJ - Estimated non-detect.

Values in **Bold** indicate the compound was detected.

Values shown in Bold and shaded type exceed the listed Action Level.

PCBs - Polychlorinated Biphenyls.

* - EPA definition of PCB Caulk pertains to any caulk sample containing >= 50 mg/kg total PCBs.

Data validation for all samples completed.

TABLE 1
Summary of Analytical Results for Caulk Samples -- June 2010
P.S. 178X
Bronx, New York

Analysis	Analyte	Sample ID:	178-357-CK- PRE-1	178-357-CK- PRE-2	178-359-CK- PRE-1	178-360-CK- PRE-1	178-364-CK- PRE-1	178-GYM1- CK-PRE-2	178-NP-CK- PRE-1	178-NP-CK- PRE-2	178-NP-CK- PRE-3	178-SP-CK- PRE-1	
			Sample Description:	Window Sill Caulk	Window Frame Caulk	Toilet/Urinal/ Sink Caulk	Sink/Toilet Caulk	Sink/Counter Caulk	Window Glaze	Sink Caulk	Sink Countertop Caulk	Sink Caulk	Drinking Fountain Caulk
			Sample Location:	Room 357	Room 357	Room 359 BR	Room 360 BR	Library	Gym 1	North Passage	North Passage	North Passage	South Passage
			Sample Date:	6/12/2010	6/12/2010	6/24/2010	6/24/2010	6/12/2010	6/24/2010	6/12/2010	6/12/2010	6/16/2010	6/24/2010
		Action Level*											
PCBs (mg/kg)													
	Aroclor 1016	N/A	0.659 U	3.31 U	0.384 UJ	0.386 UJ	0.330 U	0.330 UJ	0.329 U	0.332 U	3.28 UJ	0.836 U	
	Aroclor 1221	N/A	0.659 U	3.31 U	0.384 UJ	0.386 UJ	0.330 U	0.330 UJ	0.329 U	0.332 U	3.28 UJ	0.836 U	
	Aroclor 1232	N/A	0.659 U	3.31 U	0.384 UJ	0.386 UJ	0.330 U	0.330 UJ	0.329 U	0.332 U	3.28 UJ	0.836 U	
	Aroclor 1242	N/A	0.659 U	3.31 U	0.384 UJ	0.386 UJ	0.330 U	0.330 UJ	0.329 U	0.332 U	3.28 UJ	0.836 U	
	Aroclor 1248	N/A	0.659 U	3.31 U	0.384 UJ	0.386 UJ	0.518 J	0.330 UJ	0.329 U	0.332 U	3.28 UJ	0.836 U	
	Aroclor 1254	N/A	13.1 J	3.31 U	0.384 UJ	0.386 UJ	0.492 J	1.96 J	1.36 J	0.332 U	6.71 J	0.836 U	
	Aroclor 1260	N/A	0.659 U	57.9 J	0.384 UJ	0.386 UJ	0.330 U	0.330 UJ	0.329 U	0.332 U	3.28 UJ	0.836 U	
	Total PCBs	50	13.1 J	57.9 J	0.384 UJ	0.386 UJ	1.01 J	1.96 J	1.36 J	0.332 U	6.71 J	0.836 U	

Notes:

mg/kg - milligrams per kilogram or parts per million (ppm).

J - Estimated value.

N/A - Not applicable.

U - Compound was not detected at specified quantitation limit.

UJ - Estimated non-detect.

Values in **Bold** indicate the compound was detected.

Values shown in Bold and shaded type exceed the listed Action Level.

PCBs - Polychlorinated Biphenyls.

* - EPA definition of PCB Caulk pertains to any caulk sample containing >= 50 mg/kg total PCBs.

Data validation for all samples completed.

TABLE 1
Summary of Analytical Results for Caulk Samples -- June 2010
P.S. 178X
Bronx, New York

Analysis	Analyte	Sample ID:	178-STB-CK-	178-STB-CK-	178-STC-CK-	178-STC-CK-	178-STD-CK-	178-STD-CK-	178-STD-CK-	178-STIA-	178-STIA-	178-	
			PRE-1	PRE-2	PRE-1	PRE-2	PRE-1	PRE-2	PRE-3	CK-PRE-1	CK-PRE-2	CONTRACT	
			Door Window Glaze	Door Window Glaze	Door Window Glaze	Door Window Glaze	Door Window Glaze	Door Window Glaze	Door Window Glaze	Door Window Glaze	Door Window Glaze	Door Window Glaze	Caulk to be Used for Repairs
			Stair B	Stair B	Stair C	Stair C	Stair D	Stair D	Stair D	Room STIA	Room STIA	N/A	
		Sample Description:	6/24/2010	6/24/2010	6/24/2010	6/24/2010	6/24/2010	6/24/2010	6/24/2010	6/16/2010	6/16/2010	7/20/2010	
		Sample Location:											
		Sample Date:											
		Action Level*											
PCBs (mg/kg)	Aroclor 1016	N/A	0.386 U	0.486 U	0.568 U	0.334 U	0.332 U	0.332 U	0.334 U	0.330 U	0.327 U	0.495 U	
	Aroclor 1221	N/A	0.386 U	0.486 U	0.568 U	0.334 U	0.332 U	0.332 U	0.334 U	0.330 U	0.327 U	0.495 U	
	Aroclor 1232	N/A	0.386 U	0.486 U	0.568 U	0.334 U	0.332 U	0.332 U	0.334 U	0.330 U	0.327 U	0.495 U	
	Aroclor 1242	N/A	0.386 U	0.486 U	0.568 U	0.334 U	0.332 U	0.332 U	0.334 U	0.330 U	0.327 U	0.495 U	
	Aroclor 1248	N/A	0.386 U	0.486 U	0.568 U	1.97 J	0.332 U	0.332 U	0.334 U	0.873 J	0.327 U	0.495 U	
	Aroclor 1254	N/A	8.12 J	3.36 J	4.41 J	3.21 J	3.60 J	1.93 J	9.19 J	2.13 J	2.08 J	0.495 U	
	Aroclor 1260	N/A	0.386 U	0.486 U	0.568 U	0.334 U	0.332 U	0.332 U	0.334 U	0.330 U	0.327 U	0.495 U	
	Total PCBs	50	8.12 J	3.36 J	4.41 J	5.18 J	3.60 J	1.93 J	9.19 J	3.003 J	2.08 J	0.495 U	

Notes:

mg/kg - milligrams per kilogram or parts per million (ppm).

J - Estimated value.

N/A - Not applicable.

U - Compound was not detected at specified quantitation limit.

UJ - Estimated non-detect.

Values in **Bold** indicate the compound was detected.

Values shown in Bold and shaded type exceed the listed Action Level.

PCBs - Polychlorinated Biphenyls.

* - EPA definition of PCB Caulk pertains to any caulk sample containing >= 50 mg/kg total PCBs.

Data validation for all samples completed.

TABLE 2
Summary of Analytical Results for Caulk Samples -- June 2010
P.S. 199M
Manhattan, New York

Analysis	Analyte	Sample ID:	199-106-CK- PRE-1	199-106-CK- PRE-2	199-106-CK- PRE-3	199-108-CK- PRE-1	199-110-CK- PRE-1	199-110-CK- PRE-2	199-110-CK- PRE-3	199-112-CK- PRE-1	199-112-CK- PRE-2	199-112-CK- PRE-3
		Sample Description:	Transom Window Glaze	Sink Caulk	Toilet Caulk	Transom Window Glaze	Transom Window Glaze	Sink Caulk	Toilet Caulk	Counter Caulk	Door Header Window Glazing	Sink Valve Caulk
		Sample Location:	Room 106	Room 106	Room 106 BR	Room 108	Room 110	Room 110	Room 110 BR	Room 112	Room 112	Room 112
		Sample Date:	6/23/2010	6/23/2010	6/23/2010	6/23/2010	6/23/2010	6/23/2010	6/23/2010	6/14/2010	6/14/2010	6/14/2010
		Action Level*										
PCBs (mg/kg)												
	Aroclor 1016	N/A	0.328 U	0.330 U	1.01 U	0.333 U	0.330 U	1.79 U	0.656 U	0.327 U	0.327 U	1.33 U
	Aroclor 1221	N/A	0.328 U	0.330 U	1.01 U	0.333 U	0.330 U	1.79 U	0.656 U	0.327 U	0.327 U	1.33 U
	Aroclor 1232	N/A	0.328 U	0.330 U	1.01 U	0.333 U	0.330 U	1.79 U	0.656 U	0.327 U	0.327 U	1.33 U
	Aroclor 1242	N/A	0.328 U	0.330 U	1.01 U	0.333 U	0.330 U	1.79 U	0.656 U	0.327 U	0.327 U	1.33 U
	Aroclor 1248	N/A	1.01 J	2.26 J	1.01 U	0.808 J	0.980 J	7.89 J	0.656 U	0.327 U	0.795 J	7.39 J
	Aroclor 1254	N/A	1.86 J	2.99 J	14.0 J	1.55 J	1.87 J	16.8 J	6.01 J	3.82 J	1.66 J	8.08 J
	Aroclor 1260	N/A	0.328 U	0.330 U	1.01 U	0.333 U	0.330 U	1.79 U	0.656 U	0.327 U	0.327 U	1.33 U
	Total PCBs	50	2.87 J	5.25 J	14.0 J	2.358 J	2.85 J	24.69 J	6.01 J	3.82 J	2.455 J	15.47 J

Notes:

mg/kg - milligrams per kilogram or parts per million (ppm).

J - Estimated value.

N/A - Not applicable.

U - Compound was not detected at specified quantitation limit.

Values in **Bold** indicate the compound was detected.

Values shown in Bold and shaded type exceed the listed Action Level.

PCBs - Polychlorinated Biphenyls.

* - EPA definition of PCB Caulk pertains to any caulk sample containing >= 50 mg/kg total PCBs.

Data validation for all samples completed.

TABLE 2
Summary of Analytical Results for Caulk Samples -- June 2010
P.S. 199M
Manhattan, New York

Analysis	Analyte	Sample ID:	199-116-CK- PRE-1	199-116-CK- PRE-2	199-116-CK- PRE-3	199-116-CK- PRE-4	199-118-CK- PRE-1	199-118-CK- PRE-2	199-118-CK- PRE-3	199-120-CK- PRE-4	199-120-CK- PRE-5	199-120-CK- PRE-6
		Sample Description:	Door Header Caulk	Door Window Glaze	Sink Caulk	Toilet Caulk	Electrical Penetration Caulk	Transom Window Glaze	Toilet Caulk	Door Glazing	Counter /Cabinet Caulk	Sink Caulk
		Sample Location:	Room 116	Room 116	Room 116	Room 116 BR	Room 118	Room 118	Room 118 BR	Room 120	Room 120	Room 120
		Sample Date:	6/14/2010	6/14/2010	6/14/2010	6/23/2010	6/23/2010	6/23/2010	6/23/2010	6/11/2010	6/11/2010	6/11/2010
		Action Level*										
PCBs (mg/kg)												
	Aroclor 1016	N/A	1.15 U	1.31 U	3.31 U	2.66 U	0.333 U	1.22 U	0.999 U	1.22 U	1.69 U	0.663 U
	Aroclor 1221	N/A	1.15 U	1.31 U	3.31 U	2.66 U	0.333 U	1.22 U	0.999 U	1.22 U	1.69 U	0.663 U
	Aroclor 1232	N/A	1.15 U	1.31 U	3.31 U	2.66 U	0.333 U	1.22 U	0.999 U	1.22 U	1.69 U	0.663 U
	Aroclor 1242	N/A	1.15 U	1.31 U	3.31 U	2.66 U	0.333 U	1.22 U	0.999 U	1.22 U	1.69 U	0.663 U
	Aroclor 1248	N/A	7.86 J	9.91 J	3.31 U	12.7 J	2.40 J	13.6 J	0.999 U	1.22 U	10.5 J	9.60 J
	Aroclor 1254	N/A	20.4 J	24.7 J	52.2 J	32.5 J	2.93 J	37.5 J	9.47 J	35.2 J	7.02 J	5.65 J
	Aroclor 1260	N/A	1.15 U	1.31 U	3.31 U	2.66 U	0.333 U	1.22 U	0.999 U	1.22 U	1.69 U	0.663 U
	Total PCBs	50	28.26 J	34.61 J	52.2 J	45.2 J	5.33 J	51.1 J	9.47 J	35.2 J	17.52 J	15.25 J

Notes:

mg/kg - milligrams per kilogram or parts per million (ppm).

J - Estimated value.

N/A - Not applicable.

U - Compound was not detected at specified quantitation limit.

Values in **Bold** indicate the compound was detected.

**Values shown in Bold and shaded type exceed the listed
Action Level.**

PCBs - Polychlorinated Biphenyls.

* - EPA definition of PCB Caulk pertains to any caulk sample
containing >= 50 mg/kg total PCBs.

Data validation for all samples completed.

TABLE 2
Summary of Analytical Results for Caulk Samples -- June 2010
P.S. 199M
Manhattan, New York

Analysis	Analyte	Sample ID:	199-120-CK- PRE-7	199-124-CK- PRE-1	199-124-CK- PRE-2	199-126-CK- PRE-1	199-138-CK- PRE-1	199-138-CK- PRE-2	199-140-CK- PRE-1	199-140-CK- PRE-2	199-202-CK- PRE-1	199-204-CK- PRE-1
		Sample Description:	Bookshelf Caulk	Sink Caulk	Louvre Caulk	Toilet Caulk	Urinal Caulk	Sink Caulk	Sink Caulk	Toilet Caulk	Sink Caulk	Sink Caulk
		Sample Location:	Room 120	Room 124	Room 124	Room 126 BR	Room 138 BR	Room 138 BR	Room 140 BR	Room 140 BR	Room 202	Room 204
		Sample Date:	6/11/2010	6/23/2010	6/23/2010	6/23/2010	6/23/2010	6/23/2010	6/23/2010	6/23/2010	6/23/2010	6/23/2010
		Action Level*										
PCBs (mg/kg)												
	Aroclor 1016	N/A	0.330 U	0.657 U	0.332 U	1.67 U	0.395 U	0.333 U	0.330 U	1.36 U	1.62 U	1.97 U
	Aroclor 1221	N/A	0.330 U	0.657 U	0.332 U	1.67 U	0.395 U	0.333 U	0.330 U	1.36 U	1.62 U	1.97 U
	Aroclor 1232	N/A	0.330 U	0.657 U	0.332 U	1.67 U	0.395 U	0.333 U	0.330 U	1.36 U	1.62 U	1.97 U
	Aroclor 1242	N/A	0.330 U	0.657 U	0.332 U	1.67 U	0.395 U	0.333 U	0.330 U	1.36 U	1.62 U	1.97 U
	Aroclor 1248	N/A	8.20 J	4.70 J	0.640 J	1.67 U	0.395 U	0.333 U	2.48 J	1.36 U	1.62 U	1.97 U
	Aroclor 1254	N/A	8.24 J	5.69 J	0.511 J	8.85 J	5.78 J	7.11 J	3.07 J	10.6 J	52.0 J	36.3 J
	Aroclor 1260	N/A	0.330 U	0.657 U	0.332 U	1.67 U	0.395 U	0.333 U	0.330 U	1.36 U	1.62 U	1.97 U
	Total PCBs	50	16.44 J	10.39 J	1.151 J	8.85 J	5.78 J	7.11 J	5.55 J	10.6 J	52.0 J	36.3 J

Notes:

mg/kg - milligrams per kilogram or parts per million (ppm).

J - Estimated value.

N/A - Not applicable.

U - Compound was not detected at specified quantitation limit.

Values in **Bold** indicate the compound was detected.

**Values shown in Bold and shaded type exceed the listed
Action Level.**

PCBs - Polychlorinated Biphenyls.

* - EPA definition of PCB Caulk pertains to any caulk sample
containing >= 50 mg/kg total PCBs.

Data validation for all samples completed.

TABLE 2
Summary of Analytical Results for Caulk Samples -- June 2010
P.S. 199M
Manhattan, New York

Analysis	Analyte	Sample ID:	199-214-CK- PRE-1	199-215-CK- PRE-1	199-215-CK- PRE-2	199-215-CK- PRE-3	199-221-CK- PRE-1	199-221-CK- PRE-2	199-222-CK- PRE-1	199-234-CK- PRE-1	199-302-CK- PRE-45	199-304-CK- PRE-1
		Sample Description:	Sink Caulk	Sink/Urinal/ Toilet Caulk	Urinal/Mirror Caulk	Urinal Caulk	Mirror Caulk	Toilet Caulk	Sink Caulk	Sink Caulk	Sink Caulk	Sink Caulk
		Sample Location:	Room 214	Room 215 BR	Room 215 BR	Room 215 BR	Room 221 BR	Room 221 BR	Room 222	Room 234	Room 302	Room 304
		Sample Date:	6/14/2010	6/23/2010	6/23/2010	6/23/2010	6/14/2010	6/14/2010	6/14/2010	6/23/2010	6/12/2010	6/23/2010
		Action Level*										
PCBs (mg/kg)												
	Aroclor 1016	N/A	1.46 U	0.338 U	0.335 U	0.327 U	0.332 U	0.332 U	3.40 U	4.20 U	20.0 U	1.10 U
	Aroclor 1221	N/A	1.46 U	0.338 U	0.335 U	0.327 U	0.332 U	0.332 U	3.40 U	4.20 U	20.0 U	1.10 U
	Aroclor 1232	N/A	1.46 U	0.338 U	0.335 U	0.327 U	0.332 U	0.332 U	3.40 U	4.20 U	20.0 U	1.10 U
	Aroclor 1242	N/A	1.46 U	0.338 U	0.335 U	0.327 U	0.332 U	0.332 U	3.40 U	4.20 U	20.0 U	1.10 U
	Aroclor 1248	N/A	1.46 U	0.338 U	0.335 U	0.327 U	0.332 U	4.38 J	3.40 U	4.20 U	20.0 U	1.10 U
	Aroclor 1254	N/A	29.8 J	11.4 J	2.86 J	2.75 J	2.47 J	5.55 J	23.0 J	21.3 J	43.8 J	6.42 J
	Aroclor 1260	N/A	1.46 U	0.338 U	0.335 U	0.327 U	0.332 U	0.332 U	3.40 U	4.20 U	20.0 U	1.10 U
	Total PCBs	50	29.8 J	11.4 J	2.86 J	2.75 J	2.47 J	9.93 J	23.0 J	21.3 J	43.8 J	6.42 J

Notes:

mg/kg - milligrams per kilogram or parts per million (ppm).

J - Estimated value.

N/A - Not applicable.

U - Compound was not detected at specified quantitation limit.

Values in **Bold** indicate the compound was detected.

Values shown in Bold and shaded type exceed the listed Action Level.

PCBs - Polychlorinated Biphenyls.

* - EPA definition of PCB Caulk pertains to any caulk sample containing >= 50 mg/kg total PCBs.

Data validation for all samples completed.

TABLE 2
Summary of Analytical Results for Caulk Samples -- June 2010
P.S. 199M
Manhattan, New York

Analysis	Analyte	Sample ID:	199-306-CK- PRE-1	199-308-CK- PRE-1	199-310-CK- PRE-1	199-312-CK- PRE-38	199-314-CK- PRE-1	199-315-CK- PRE-1	199-315-CK- PRE-2	199-315-CK- PRE-3	199-315-CK- PRE-4	199-316-CK- PRE-1
		Sample Description:	Sink Caulk	Sink Caulk	Sink Caulk	Door Window Glazing	Sink Caulk	Sink Caulk	Urinal Caulk	Urinal Caulk	Toilet Caulk	Sink Caulk
		Sample Location:	Room 306	Room 308	Room 310	Room 312	Room 314	Room 315 BR	Room 315 BR	Room 315 BR	Room 315 BR	Room 316
		Sample Date:	6/23/2010	6/23/2010	6/23/2010	6/12/2010	6/23/2010	6/23/2010	6/23/2010	6/23/2010	6/23/2010	6/23/2010
		Action Level*										
PCBs (mg/kg)												
	Aroclor 1016	N/A	2.07 U	2.00 U	2.23 U	3.31 U	3.60 U	0.648 U	0.491 U	0.326 U	0.863 U	5.56 U
	Aroclor 1221	N/A	2.07 U	2.00 U	2.23 U	3.31 U	3.60 U	0.648 U	0.491 U	0.326 U	0.863 U	5.56 U
	Aroclor 1232	N/A	2.07 U	2.00 U	2.23 U	3.31 U	3.60 U	0.648 U	0.491 U	0.326 U	0.863 U	5.56 U
	Aroclor 1242	N/A	2.07 U	2.00 U	2.23 U	3.31 U	3.60 U	0.648 U	0.491 U	0.326 U	0.863 U	5.56 U
	Aroclor 1248	N/A	2.07 U	2.00 U	2.23 U	8.68 J	3.60 U	0.648 U	0.491 U	0.326 U	0.863 U	5.56 U
	Aroclor 1254	N/A	46.4 J	86.8 J	25.1 J	16.0 J	44.8 J	16.8 J	3.70 J	3.71 J	25.1 J	52.2 J
	Aroclor 1260	N/A	2.07 U	2.00 U	2.23 U	3.31 U	3.60 U	0.648 U	0.491 U	0.326 U	0.863 U	5.56 U
	Total PCBs	50	46.4 J	86.8 J	25.1 J	24.68 J	44.8 J	16.8 J	3.70 J	3.71 J	25.1 J	52.2 J

Notes:

mg/kg - milligrams per kilogram or parts per million (ppm).

J - Estimated value.

N/A - Not applicable.

U - Compound was not detected at specified quantitation limit.

Values in **Bold** indicate the compound was detected.

**Values shown in Bold and shaded type exceed the listed
Action Level.**

PCBs - Polychlorinated Biphenyls.

* - EPA definition of PCB Caulk pertains to any caulk sample
containing >= 50 mg/kg total PCBs.

Data validation for all samples completed.

TABLE 2
Summary of Analytical Results for Caulk Samples -- June 2010
P.S. 199M
Manhattan, New York

Analysis	Analyte	Sample ID:	199-318-CK- PRE-1	199-320-CK- PRE-1	199-321-CK- PRE-1	199-321-CK- PRE-2	199-321-CK- PRE-3	199-322-CK- PRE-1	199-324-CK- PRE-1	199-326-CK- PRE-1	199-328-CK- PRE-1	199-336-CK- PRE-1
		Sample Description:	Sink Caulk	Sink Caulk	Mirror Caulk	Sink Caulk	Toilet Caulk	Sink Caulk	Sink Caulk	Sink Caulk	Sink Caulk	Sink Caulk
		Sample Location:	Room 318	Room 320	Room 321 BR	Room 321 BR	Room 321 BR	Room 322	Room 324	Room 326	Room 328	Room 336
		Sample Date:	6/23/2010	6/23/2010	6/23/2010	6/23/2010	6/23/2010	6/14/2010	6/23/2010	6/23/2010	6/23/2010	6/14/2010
		Action Level*										
PCBs (mg/kg)												
	Aroclor 1016	N/A	2.02 U	11.4 U	0.664 U	0.732 U	0.699 U	0.443 U	2.08 U	6.02 U	3.73 U	2.98 U
	Aroclor 1221	N/A	2.02 U	11.4 U	0.664 U	0.732 U	0.699 U	0.443 U	2.08 U	6.02 U	3.73 U	2.98 U
	Aroclor 1232	N/A	2.02 U	11.4 U	0.664 U	0.732 U	0.699 U	0.443 U	2.08 U	6.02 U	3.73 U	2.98 U
	Aroclor 1242	N/A	2.02 U	11.4 U	0.664 U	0.732 U	0.699 U	0.443 U	2.08 U	6.02 U	3.73 U	2.98 U
	Aroclor 1248	N/A	2.02 U	11.4 U	8.39 J	0.732 U	0.699 U	0.443 U	2.08 U	6.02 U	3.73 U	2.98 U
	Aroclor 1254	N/A	57.7 J	60.1 J	15.8 J	20.2 J	26.0 J	11.8 J	44.1 J	47.7 J	71.2 J	7.47 J
	Aroclor 1260	N/A	2.02 U	11.4 U	0.664 U	0.732 U	0.699 U	0.443 U	2.08 U	6.02 U	3.73 U	2.98 U
	Total PCBs	50	57.7 J	60.1 J	24.19 J	20.2 J	26.0 J	11.8 J	44.1 J	47.7 J	71.2 J	7.47 J

Notes:

mg/kg - milligrams per kilogram or parts per million (ppm).

J - Estimated value.

N/A - Not applicable.

U - Compound was not detected at specified quantitation limit.

Values in **Bold** indicate the compound was detected.

Values shown in Bold and shaded type exceed the listed Action Level.

PCBs - Polychlorinated Biphenyls.

* - EPA definition of PCB Caulk pertains to any caulk sample containing >= 50 mg/kg total PCBs.

Data validation for all samples completed.

TABLE 2
Summary of Analytical Results for Caulk Samples -- June 2010
P.S. 199M
Manhattan, New York

Analysis	Analyte	Sample ID:	199-CAFE-CK-PRE-16	199-CAFE-CK-PRE-17	199-CAFE-CK-PRE-18	199-CAFE-CK-PRE-19	199-CAFE-CK-PRE-20	199-GYM-CK-PRE-1	199-GYM-CK-PRE-2	199-GYM-CK-PRE-3	199-GYM-CK-PRE-4	199-GYM-CK-PRE-5
		Sample Description:	Metal Door Frame Caulk	Door Window and Header Glaze	Door Window Glaze	Bay Door Frame Caulk	Door Frame Caulk	Penetration Caulk	Door Frame Caulk	Sink Caulk	Bay Door Frame Caulk	Metal Door Window Glaze
		Sample Location:	Cafeteria	Cafeteria	Cafeteria	Cafeteria	Cafeteria	Gym	Gym	Gym	Gym	Gym
		Sample Date:	6/12/2010	6/12/2010	6/12/2010	6/12/2010	6/12/2010	6/14/2010	6/14/2010	6/14/2010	6/14/2010	6/14/2010
		Action Level*										
PCBs (mg/kg)												
	Aroclor 1016	N/A	3,290 U	3.30 U	2.25 U	3,340 U	1,330 U	4.22 U	6,670 U	3.33 U	6,600 U	8.74 U
	Aroclor 1221	N/A	3,290 U	3.30 U	2.25 U	3,340 U	1,330 U	4.22 U	6,670 U	3.33 U	6,600 U	8.74 U
	Aroclor 1232	N/A	3,290 U	3.30 U	2.25 U	3,340 U	1,330 U	4.22 U	6,670 U	3.33 U	6,600 U	8.74 U
	Aroclor 1242	N/A	3,290 U	3.30 U	2.25 U	3,340 U	1,330 U	4.22 U	6,670 U	3.33 U	6,600 U	8.74 U
	Aroclor 1248	N/A	3,290 U	3.30 U	2.25 U	3,340 U	1,330 U	4.22 U	6,670 U	3.33 U	6,600 U	8.74 U
	Aroclor 1254	N/A	112,000 J	50.6 J	41.3 J	146,000 J	57,100 J	68.4 J	117,000 J	7.42 U	137,000 J	14.6 U
	Aroclor 1260	N/A	3,290 U	3.30 U	2.25 U	3,340 U	1,330 U	4.22 U	6,670 U	3.33 U	6,600 U	8.74 U
	Total PCBs	50	112,000 J	50.6 J	41.3 J	146,000 J	57,100 J	68.4 J	117,000 J	7.42 U	137,000 J	14.6 U

Notes:

mg/kg - milligrams per kilogram or parts per million (ppm).

J - Estimated value.

N/A - Not applicable.

U - Compound was not detected at specified quantitation limit.

Values in **Bold** indicate the compound was detected.

Values shown in Bold and shaded type exceed the listed Action Level.

PCBs - Polychlorinated Biphenyls.

* - EPA definition of PCB Caulk pertains to any caulk sample containing >= 50 mg/kg total PCBs.

Data validation for all samples completed.

TABLE 2
Summary of Analytical Results for Caulk Samples -- June 2010
P.S. 199M
Manhattan, New York

Analysis	Analyte	Sample ID:	199-ME-CK- PRE-8	199-ME-CK- PRE-9	199-ME-CK- PRE-10	199-ME-CK- PRE-12	199-NC-CK- PRE-1	199-NC-CK- PRE-2	199-NC-CK- PRE-4	199-NC-CK- PRE-6
		Sample Description:	Door Frame Caulk	Door Window Frame Caulk	Door Frame Caulk (Sides)	Door Frame Caulk (Sides)	Door Frame Caulk	Caulk above Fire Extinguisher	Metal Door Window Glaze	Wall Panel Caulk
		Sample Location:	Main Entrance	Main Entrance	Main Entrance	Main Entrance	3rd Floor North Corridor	3rd Floor North Corridor	3rd Floor North Corridor	3rd Floor North Corridor
		Sample Date:	6/11/2010	6/11/2010	6/11/2010	6/11/2010	6/14/2010	6/14/2010	6/14/2010	6/14/2010
		Action Level*								
PCBs (mg/kg)	Aroclor 1016	N/A	1.58 U	1.64 U	1,760 U	2,060 U	6,610 U	6,590 U	3.33 U	6,640 U
	Aroclor 1221	N/A	1.58 U	1.64 U	1,760 U	2,060 U	6,610 U	6,590 U	3.33 U	6,640 U
	Aroclor 1232	N/A	1.58 U	1.64 U	1,760 U	2,060 U	6,610 U	6,590 U	3.33 U	6,640 U
	Aroclor 1242	N/A	1.58 U	1.64 U	1,760 U	2,060 U	6,610 U	6,590 U	3.33 U	6,640 U
	Aroclor 1248	N/A	24.5 J	4.73 J	1,760 U	2,060 U	6,610 U	6,590 U	3.33 U	6,640 U
	Aroclor 1254	N/A	39.7 J	1.95 J	78,500 J	84,500 J	243,000 J	165,000 J	88.0 J	217,000 J
	Aroclor 1260	N/A	1.58 U	1.64 U	1,760 U	2,060 U	6,610 U	6,590 U	3.33 U	6,640 U
	Total PCBs	50	64.2 J	6.68 J	78,500 J	84,500 J	243,000 J	165,000 J	88.0 J	217,000 J

Notes:

mg/kg - milligrams per kilogram or parts per million (ppm).

J - Estimated value.

N/A - Not applicable.

U - Compound was not detected at specified quantitation limit.

Values in **Bold** indicate the compound was detected.

Values shown in **Bold and shaded type** exceed the listed

Action Level.

PCBs - Polychlorinated Biphenyls.

* - EPA definition of PCB Caulk pertains to any caulk sample containing >= 50 mg/kg total PCBs.

Data validation for all samples completed.

TABLE 3
Summary of Analytical Results for Caulk Samples -- June and July 2010
P.S. 309K
Brooklyn, New York

Analysis	Analyte	Sample ID:	309-100-CK- PRE-1	309-100-CK- PRE-2	309-102-CK- PRE-1	309-103-CK- PRE-1	309-103-CK- PRE-2	309-103-CK- PRE-3	309-103-CK- PRE-4	309-104-CK- PRE-3	309-104-CK- PRE-4	309-106-CK- PRE-1
		Sample Description:	Electrical Penetration Caulk	Sink Caulk	Electrical Penetration Caulk	Sink Caulk	Sink Caulk	Urinal Caulk	Toilet Caulk	Electrical Penetration Caulk	Sink Caulk (underside)	Electrical Penetration Caulk
		Sample Location:	Room 100	Room 100	Room 102	Room 103 BR	Room 103 BR	Room 103 BR	Room 103 BR	Room 104	Room 104	Room 106
		Sample Date:	6/28/2010	6/28/2010	6/28/2010	6/28/2010	6/28/2010	6/28/2010	6/28/2010	6/17/2010	6/17/2010	6/28/2010
		Action Level*										
PCBs (mg/kg)	Aroclor 1016	N/A	0.346 U	0.666 U	0.331 U	0.330 U	0.353 U	0.332 U	0.665 U	0.654 U	0.329 U	0.333 U
	Aroclor 1221	N/A	0.346 U	0.666 U	0.331 U	0.330 U	0.353 U	0.332 U	0.665 U	0.654 U	0.329 U	0.333 U
	Aroclor 1232	N/A	0.346 U	0.666 U	0.331 U	0.330 U	0.353 U	0.332 U	0.665 U	0.654 U	0.329 U	0.333 U
	Aroclor 1242	N/A	0.346 U	0.666 U	0.331 U	0.330 U	0.353 U	0.332 U	0.665 U	0.654 U	0.329 U	0.333 U
	Aroclor 1248	N/A	2.99 J	0.666 U	3.51 J	0.330 U	1.353 U	0.332 U	1.87 J	5.68 J	0.329 U	2.69 J
	Aroclor 1254	N/A	4.20 J	2.92 J	5.70 J	5.43 J	13.6 J	3.91 J	4.69 J	12.7 J	4.60 J	2.65 J
	Aroclor 1260	N/A	0.346 U	0.666 U	0.331 U	0.330 U	0.353 U	0.332 U	0.665 U	0.654 U	0.329 U	0.333 U
	Total PCBs	50	7.19 J	2.92 J	9.21 J	5.43 J	13.6 J	3.91 J	6.56 J	18.38 J	4.60 J	5.34 J

Notes:

mg/kg - milligrams per kilogram or parts per million (ppm).

J - Estimated value.

N/A - Not applicable.

U - Compound was not detected at specified quantitation limit.

UJ - Estimated non-detect.

Values in **Bold** indicate the compound was detected.

Values shown in **Bold and shaded type** exceed the listed Action Level.

PCBs - Polychlorinated Biphenyls.

* - EPA definition of PCB Caulk pertains to any caulk sample containing >= 50 mg/kg total PCBs.

Data validation for all samples completed.

TABLE 3
Summary of Analytical Results for Caulk Samples -- June and July 2010
P.S. 309K
Brooklyn, New York

Analysis	Analyte	Sample ID:	309-106-CK- PRE-2	309-109-CK- PRE-1	309-109-CK- PRE-2	309-109-CK- PRE-3	309-116-CK- PRE-3	309-116-CK- PRE-4	309-118-CK- PRE-1	309-118-CK- PRE-2	309-120T- CK-PRE-1	309-141-CK- PRE-1
		Sample Description:	Sink Caulk	Sink Caulk	Sink Caulk	Toilet Caulk	Electrical Penetration Caulk	Sink Caulk (underside)	Sink Caulk	Electrical Penetration Caulk	Toilet Caulk	Sink Caulk
		Sample Location:	Room 106	Room 109 BR	Room 109 BR	Room 109 BR	Room 116	Room 116	Room 118	Room 118	Room 120T BR	Room 141
		Sample Date:	6/28/2010	6/28/2010	6/28/2010	6/28/2010	6/17/2010	6/17/2010	6/28/2010	6/28/2010	6/28/2010	6/28/2010
Action Level*												
PCBs (mg/kg)	Aroclor 1016	N/A	0.332 U	0.734 U	0.667 U	0.660 U	0.334 U	0.462 U	0.331 U	0.757 U	0.332 U	29.4 UJ
	Aroclor 1221	N/A	0.332 U	0.734 U	0.667 U	0.660 U	0.334 U	0.462 U	0.331 U	0.757 U	0.332 U	29.4 UJ
	Aroclor 1232	N/A	0.332 U	0.734 U	0.667 U	0.660 U	0.334 U	0.462 U	0.331 U	0.757 U	0.332 U	29.4 UJ
	Aroclor 1242	N/A	0.332 U	0.734 U	0.667 U	0.660 U	0.334 U	0.462 U	0.331 U	0.757 U	0.332 U	29.4 UJ
	Aroclor 1248	N/A	1.25 J	3.74 J	0.667 U	0.660 U	3.19 J	1.22 J	1.99 J	5.50 J	1.07 J	29.4 UJ
	Aroclor 1254	N/A	1.94 J	10.4 J	15.0 J	15.2 J	4.36 J	2.01 J	3.35 J	8.32 J	2.20 J	29.4 UJ
	Aroclor 1260	N/A	0.332 U	0.734 U	0.667 U	0.660 U	0.334 U	0.462 U	0.331 U	0.757 U	0.332 U	29.4 UJ
	Total PCBs	50	3.19 J	14.14 J	15.0 J	15.2 J	7.55 J	3.23 J	5.34 J	13.82 J	3.27 J	29.4 UJ

Notes:

mg/kg - milligrams per kilogram or parts per million (ppm).

J - Estimated value.

N/A - Not applicable.

U - Compound was not detected at specified quantitation limit.

UJ - Estimated non-detect.

Values in **Bold** indicate the compound was detected.

Values shown in **Bold and shaded type** exceed the listed Action Level.

PCBs - Polychlorinated Biphenyls.

* - EPA definition of PCB Caulk pertains to any caulk sample containing >= 50 mg/kg total PCBs.

Data validation for all samples completed.

TABLE 3
Summary of Analytical Results for Caulk Samples -- June and July 2010
P.S. 309K
Brooklyn, New York

Analysis	Analyte	Sample ID:	309-141-CK- PRE-2	309-143-CK- PRE-3	309-143-CK- PRE-4	309-145-CK- PRE-1	309-147-CK- PRE-1	309-147-CK- PRE-2	309-149-CK- PRE-1	309-149-CK- PRE-2	309-200-CK- PRE-1	309-200-CK- PRE-2
		Sample Description:	Toilet Caulk	Door Window Glaze	Sink Caulk	Sink Caulk	Sink Caulk	Toilet Caulk	Electrical Penetration Caulk	Sink Caulk	Electrical Penetration Caulk	Under Sink Caulk
		Sample Location:	Room 141 BR	Room 143	Room 143	Room 145	Room 147	Room 147 BR	Room 149	Room 149	Room 200	Room 200
		Sample Date:	6/28/2010	6/13/2010	6/28/2010	6/28/2010	6/28/2010	6/28/2010	6/28/2010	6/28/2010	6/25/2010	6/25/2010
		Action Level*										
PCBs (mg/kg)												
	Aroclor 1016	N/A	0.333 U	3.26 U	79.4 UJ	23.3 UJ	3.27 U	0.328 U	3.32 U	0.333 U	0.331 U	0.663 U
	Aroclor 1221	N/A	0.333 U	3.26 U	79.4 UJ	23.3 UJ	3.27 U	0.328 U	3.32 U	0.333 U	0.331 U	0.663 U
	Aroclor 1232	N/A	0.333 U	3.26 U	79.4 UJ	23.3 UJ	3.27 U	0.328 U	3.32 U	0.333 U	0.331 U	0.663 U
	Aroclor 1242	N/A	0.333 U	3.26 U	79.4 UJ	23.3 UJ	3.27 U	0.328 U	3.32 U	0.333 U	0.331 U	0.663 U
	Aroclor 1248	N/A	0.333 U	3.26 U	79.4 UJ	23.3 UJ	3.27 U	2.60 J	9.77 J	0.333 U	4.71 J	0.663 U
	Aroclor 1254	N/A	2.28 J	6.11 J	79.4 UJ	23.3 UJ	1.79 J	5.03 J	16.7 J	6.09 J	7.43 J	4.55 J
	Aroclor 1260	N/A	0.333 U	3.26 U	79.4 UJ	23.3 UJ	3.27 U	0.328 U	3.32 U	0.333 U	0.331 U	0.663 U
	Total PCBs	50	2.28 J	6.11 J	79.4 UJ	23.3 UJ	1.79 J	7.63 J	26.47 J	6.09 J	12.14 J	4.55 J

Notes:

mg/kg - milligrams per kilogram or parts per million (ppm).

J - Estimated value.

N/A - Not applicable.

U - Compound was not detected at specified quantitation limit.

UJ - Estimated non-detect.

Values in **Bold** indicate the compound was detected.

Values shown in **Bold and shaded type** exceed the listed
Action Level.

PCBs - Polychlorinated Biphenyls.

* - EPA definition of PCB Caulk pertains to any caulk sample
containing >= 50 mg/kg total PCBs.

Data validation for all samples completed.

TABLE 3
Summary of Analytical Results for Caulk Samples -- June and July 2010
P.S. 309K
Brooklyn, New York

Analysis	Analyte	Sample ID:	309-202-CK- PRE-1	309-202-CK- PRE-2	309-204-CK- PRE-1	309-204-CK- PRE-2	309-205-CK- PRE-1	309-205-CK- PRE-2	309-206-CK- PRE-1	309-206-CK- PRE-2	309-207-CK- PRE-1	309-207-CK- PRE-2
		Sample Description:	Electrical Penetration Caulk	Under Sink Caulk	Electrical Penetration Caulk	Under Sink Caulk	Electrical Penetration Caulk	Under Sink Caulk	Sink Caulk (underside)	Electrical Penetration Caulk	Electrical Penetration Caulk	Water Fountain Caulk
		Sample Location:	Room 202	Room 202	Room 204	Room 204	Room 205	Room 205	Room 206	Room 206	Room 207	Room 207
		Sample Date:	6/25/2010	6/25/2010	6/25/2010	6/25/2010	6/25/2010	6/25/2010	6/17/2010	6/17/2010	6/13/2010	6/13/2010
Action Level*												
PCBs (mg/kg)	Aroclor 1016	N/A	1.31 U	0.664 U	0.657 U	0.425 U	0.662 U	1.05 U	0.328 U	0.327 U	1.87 U	1.53 U
	Aroclor 1221	N/A	1.31 U	0.664 U	0.657 U	0.425 U	0.662 U	1.05 U	0.328 U	0.327 U	1.87 U	1.53 U
	Aroclor 1232	N/A	1.31 U	0.664 U	0.657 U	0.425 U	0.662 U	1.05 U	0.328 U	0.327 U	1.87 U	1.53 U
	Aroclor 1242	N/A	1.31 U	0.664 U	0.657 U	0.425 U	0.662 U	1.05 U	0.328 U	0.327 U	1.87 U	1.53 U
	Aroclor 1248	N/A	1.31 U	0.664 U	0.657 U	0.425 U	6.98 J	1.05 U	0.328 U	0.327 U	10.7 J	5.22 J
	Aroclor 1254	N/A	6.17 J	5.27 J	6.32 J	5.84 J	13.5 J	20.6 J	6.85 J	3.00 J	29.1 J	13.8 J
	Aroclor 1260	N/A	1.31 U	0.664 U	0.657 U	0.425 U	0.662 U	1.05 U	0.328 U	0.327 U	1.87 U	1.53 U
	Total PCBs	50	6.17 J	5.27 J	6.32 J	5.84 J	20.48 J	20.6 J	6.85 J	3.00 J	39.8 J	19.02 J

Notes:

mg/kg - milligrams per kilogram or parts per million (ppm).

J - Estimated value.

N/A - Not applicable.

U - Compound was not detected at specified quantitation limit.

UJ - Estimated non-detect.

Values in **Bold** indicate the compound was detected.

Values shown in Bold and shaded type exceed the listed Action Level.

PCBs - Polychlorinated Biphenyls.

* - EPA definition of PCB Caulk pertains to any caulk sample containing >= 50 mg/kg total PCBs.

Data validation for all samples completed.

TABLE 3
Summary of Analytical Results for Caulk Samples -- June and July 2010
P.S. 309K
Brooklyn, New York

Analysis	Analyte	Sample ID:	309-207-CK- PRE-5	309-209-CK- PRE-1	309-209-CK- PRE-2	309-210-CK- PRE-1	309-210-CK- PRE-2	309-211-CK- PRE-4	309-211-CK- PRE-5	309-212-CK- PRE-1	309-212-CK- PRE-2	309-214-CK- PRE-1
		Sample Description:	Sink Caulk (underside)	Electrical Penetration Caulk	Under Sink Caulk	Electrical Penetration Caulk	Under Sink Caulk	Sink Caulk	Electrical Penetration Caulk	Electrical Penetration Caulk	Under Sink Caulk	Electrical Penetration Caulk
		Sample Location:	Room 207	Room 209	Room 209	Room 210	Room 210	Room 211 Library	Room 211 Library	Room 212	Room 212	Room 214
		Sample Date:	6/17/2010	6/25/2010	6/25/2010	6/25/2010	6/25/2010	6/13/2010	6/13/2010	6/25/2010	6/25/2010	6/25/2010
		Action Level*										
PCBs (mg/kg)												
	Aroclor 1016	N/A	1.33 U	0.665 U	0.751 U	0.993 U	7.46 U	1.06 U	1.74 U	0.745 U	1.32 U	0.669 U
	Aroclor 1221	N/A	1.33 U	0.665 U	0.751 U	0.993 U	7.46 U	1.06 U	1.74 U	0.745 U	1.32 U	0.669 U
	Aroclor 1232	N/A	1.33 U	0.665 U	0.751 U	0.993 U	7.46 U	1.06 U	1.74 U	0.745 U	1.32 U	0.669 U
	Aroclor 1242	N/A	1.33 U	0.665 U	0.751 U	0.993 U	7.46 U	1.06 U	1.74 U	0.745 U	1.32 U	0.669 U
	Aroclor 1248	N/A	1.33 U	2.34 J	0.751 U	0.993 U	7.46 U	1.06 U	1.74 U	4.28 J	5.26 J	0.669 U
	Aroclor 1254	N/A	43.6 J	4.81 J	10.7 J	3.43 J	7.46 U	15.8 J	31.7 J	6.21 J	14.2 J	8.21 J
	Aroclor 1260	N/A	1.33 U	0.665 U	0.751 U	0.993 U	7.46 U	1.06 U	1.74 U	0.745 U	1.32 U	0.669 U
	Total PCBs	50	43.6 J	7.15 J	10.7 J	3.43 J	7.46 U	15.8 J	31.7 J	10.49 J	19.46 J	8.21 J

Notes:

mg/kg - milligrams per kilogram or parts per million (ppm).

J - Estimated value.

N/A - Not applicable.

U - Compound was not detected at specified quantitation limit.

UJ - Estimated non-detect.

Values in **Bold** indicate the compound was detected.

Values shown in **Bold and shaded type** exceed the listed Action Level.

PCBs - Polychlorinated Biphenyls.

* - EPA definition of PCB Caulk pertains to any caulk sample containing >= 50 mg/kg total PCBs.

Data validation for all samples completed.

TABLE 3
Summary of Analytical Results for Caulk Samples -- June and July 2010
P.S. 309K
Brooklyn, New York

Analysis	Analyte	Sample ID:	309-214-CK- PRE-2	309-215-CK- PRE-1	309-216-CK- PRE-1	309-216-CK- PRE-2	309-218-CK- PRE-1	309-218-CK- PRE-2	309-220-CK- PRE-4	309-220-CK- PRE-5	309-239-CK- PRE-1	309-243-CK- PRE-1
		Sample Description:	Under Sink Caulk	Urinal/Sink Caulk	Electrical Penetration Caulk	Under Sink Caulk	Electrical Penetration Caulk	Under Sink Caulk	Electrical Penetration Caulk	Sink Caulk	Electrical Penetration Caulk	Electrical Penetration Caulk
		Sample Location:	Room 214	Room 215 BR	Room 216	Room 216	Room 218	Room 218	Room 220	Room 220	Room 239	Room 243
		Sample Date:	6/25/2010	6/25/2010	6/25/2010	6/25/2010	6/25/2010	6/25/2010	6/13/2010	6/13/2010	6/25/2010	6/25/2010
Action Level*												
PCBs (mg/kg)	Aroclor 1016	N/A	0.545 U	0.329 U	0.658 U	0.692 U	0.668 U	0.660 U	0.390 U	0.328 U	0.986 U	0.649 U
	Aroclor 1221	N/A	0.545 U	0.329 U	0.658 U	0.692 U	0.668 U	0.660 U	0.390 U	0.328 U	0.986 U	0.649 U
	Aroclor 1232	N/A	0.545 U	0.329 U	0.658 U	0.692 U	0.668 U	0.660 U	0.390 U	0.328 U	0.986 U	0.649 U
	Aroclor 1242	N/A	0.545 U	0.329 U	0.658 U	0.692 U	0.668 U	0.660 U	0.390 U	0.328 U	0.986 U	0.649 U
	Aroclor 1248	N/A	0.545 U	0.329 U	0.658 U	0.692 U	3.97 J	0.660 U	0.390 U	0.328 U	0.986 U	0.649 U
	Aroclor 1254	N/A	5.30 J	4.11 J	2.82 J	6.97 J	6.93 J	5.74 J	12.4 J	11.1 J	25.6 J	10.2 J
	Aroclor 1260	N/A	0.545 U	0.329 U	0.658 U	0.692 U	0.668 U	0.660 U	0.390 U	0.328 U	0.986 U	0.649 U
	Total PCBs	50	5.30 J	4.11 J	2.82 J	6.97 J	10.9 J	5.74 J	12.4 J	11.1 J	25.6 J	10.2 J

Notes:

mg/kg - milligrams per kilogram or parts per million (ppm).

J - Estimated value.

N/A - Not applicable.

U - Compound was not detected at specified quantitation limit.

UJ - Estimated non-detect.

Values in **Bold** indicate the compound was detected.

Values shown in **Bold and shaded type** exceed the listed Action Level.

PCBs - Polychlorinated Biphenyls.

* - EPA definition of PCB Caulk pertains to any caulk sample containing >= 50 mg/kg total PCBs.

Data validation for all samples completed.

TABLE 3
Summary of Analytical Results for Caulk Samples -- June and July 2010
P.S. 309K
Brooklyn, New York

Analysis	Analyte	Sample ID:	309-243-CK- PRE-2	309-249-CK- PRE-2	309-300-CK- PRE-2	309-300-CK- PRE-4	309-300-CK- PRE-5	309-302-CK- PRE-1	309-304-CK- PRE-1	309-307-CK- PRE-1	309-309-CK- PRE-1	309-310-CK- PRE-1	
		Sample Description:	Under Sink Caulk	Under Sink Caulk	Electrical Penetration Caulk	Sink Caulk	Sink Caulk	Electrical Penetration Caulk	Electrical Penetration Caulk	Electrical Penetration Caulk	Electrical Penetration Caulk	Electrical Penetration Caulk	Electrical Penetration Caulk
		Sample Location:	Room 243	Room 249	Room 300	Room 300	Room 300	Room 302	Room 304	Room 307	Room 309	Room 310	Room 310
		Sample Date:	6/25/2010	6/25/2010	6/13/2010	6/13/2010	6/13/2010	6/25/2010	6/25/2010	6/25/2010	6/25/2010	6/25/2010	6/25/2010
Action Level*													
PCBs (mg/kg)	Aroclor 1016	N/A	3.07 U	0.326 U	0.660 U	3.58 U	0.332 U	0.661 U	0.669 U	1.35 U	0.988 U	1.33 U	
	Aroclor 1221	N/A	3.07 U	0.326 U	0.660 U	3.58 U	0.332 U	0.661 U	0.669 U	1.35 U	0.988 U	1.33 U	
	Aroclor 1232	N/A	3.07 U	0.326 U	0.660 U	3.58 U	0.332 U	0.661 U	0.669 U	1.35 U	0.988 U	1.33 U	
	Aroclor 1242	N/A	3.07 U	0.326 U	0.660 U	3.58 U	0.332 U	0.661 U	0.669 U	1.35 U	0.988 U	1.33 U	
	Aroclor 1248	N/A	3.07 U	0.326 U	3.15 J	16.6 J	1.80 J	12.3 J	0.669 U	1.35 U	0.988 U	4.33 J	
	Aroclor 1254	N/A	4.69 J	10.2 J	6.51 J	18.8 J	4.28 J	8.40 J	5.21 J	17.3 J	9.67 J	5.12 J	
	Aroclor 1260	N/A	3.07 U	0.326 U	0.660 U	3.58 U	0.332 U	0.661 U	0.669 U	1.35 U	0.988 U	1.33 U	
	Total PCBs	50	4.69 J	10.2 J	9.66 J	35.4 J	6.08 J	20.7 J	5.21 J	17.3 J	9.67 J	9.45 J	

Notes:

mg/kg - milligrams per kilogram or parts per million (ppm).

J - Estimated value.

N/A - Not applicable.

U - Compound was not detected at specified quantitation limit.

UJ - Estimated non-detect.

Values in **Bold** indicate the compound was detected.

Values shown in **Bold and shaded type** exceed the listed Action Level.

PCBs - Polychlorinated Biphenyls.

* - EPA definition of PCB Caulk pertains to any caulk sample containing >= 50 mg/kg total PCBs.

Data validation for all samples completed.

TABLE 3
Summary of Analytical Results for Caulk Samples -- June and July 2010
P.S. 309K
Brooklyn, New York

Analysis	Analyte	Sample ID:	309-312-CK- PRE-2	309-312-CK- PRE-4	309-315-CK- PRE-1	309-315-CK- PRE-3	309-316-CK- PRE-1	309-318-CK- PRE-1	309-321-CK- PRE-2	309-343-CK- PRE-1	309-349-CK- PRE-1	309-CAFE- CK-PRE-3
		Sample Description:	Access Panel Caulk	Electrical Penetration Caulk	Urinal Caulk	Sink Caulk	Electrical Penetration Caulk	Electrical Penetration Caulk	Toilet Caulk	Electrical Penetration Caulk	Electrical Penetration Caulk	Metal Door Window Glaze
		Sample Location:	Room 312	Room 312	Room 315 BR	Room 315 BR	Room 316	Room 318	Room 321 Girls BR	Room 343	Room 349	Cafeteria
		Sample Date:	6/13/2010	6/13/2010	6/25/2010	6/25/2010	6/25/2010	6/25/2010	6/13/2010	6/25/2010	6/25/2010	6/13/2010
		Action Level*										
PCBs (mg/kg)												
	Aroclor 1016	N/A	3.94 U	1.32 U	0.881 U	0.773 U	0.659 U	0.662 U	1.05 UJ	0.655 U	0.668 U	0.664 U
	Aroclor 1221	N/A	3.94 U	1.32 U	0.881 U	0.773 U	0.659 U	0.662 U	1.05 UJ	0.655 U	0.668 U	0.664 U
	Aroclor 1232	N/A	3.94 U	1.32 U	0.881 U	0.773 U	0.659 U	0.662 U	1.05 UJ	0.655 U	0.668 U	0.664 U
	Aroclor 1242	N/A	3.94 U	1.32 U	0.881 U	0.773 U	0.659 U	0.662 U	1.05 UJ	0.655 U	0.668 U	0.664 U
	Aroclor 1248	N/A	3.94 U	7.25 J	1.93 J	2.07 J	2.47 J	2.21 J	1.05 UJ	0.655 U	3.13 J	0.664 U
	Aroclor 1254	N/A	7.70 J	10.0 J	4.52 J	6.97 J	3.34 J	2.75 J	3.20 J	7.39 J	6.60 J	20.1 J
	Aroclor 1260	N/A	3.94 U	1.32 U	0.881 U	0.773 U	0.659 U	0.662 U	1.05 UJ	0.655 U	0.668 U	0.664 U
	Total PCBs	50	7.70 J	17.25 J	6.45 J	9.04 J	5.81 J	4.96 J	3.20 J	7.39 J	9.73 J	20.1 J

Notes:

mg/kg - milligrams per kilogram or parts per million (ppm).

J - Estimated value.

N/A - Not applicable.

U - Compound was not detected at specified quantitation limit.

UJ - Estimated non-detect.

Values in **Bold** indicate the compound was detected.

Values shown in **Bold and shaded type** exceed the listed Action Level.

PCBs - Polychlorinated Biphenyls.

* - EPA definition of PCB Caulk pertains to any caulk sample containing \geq 50 mg/kg total PCBs.

Data validation for all samples completed.

TABLE 3
Summary of Analytical Results for Caulk Samples -- June and July 2010
P.S. 309K
Brooklyn, New York

Analysis	Analyte	Sample ID:	309-CAFE-CK-PRE-4	309-CAFE-CK-PRE-5	309-CAFE-CK-PRE-6	309-CAFE-CK-PRE-7	309-GYM-CK-PRE-2	309-GYM-CK-PRE-3	309-NS-CK-PRE-1	309-NS-CK-PRE-2	309-NS-CK-PRE-6	309-NS-CK-PRE-7
		Sample Description:	Door Frame Caulk	Metal Door Window Glaze	Bay Door Frame Caulk	Column/Wall Seam	Heat Vent Caulk	Door Frame Caulk	Door Frame Caulk	Door Window Glaze	Ceiling Joint Caulk	Door Frame Caulk
		Sample Location:	Cafeteria	Cafeteria	Cafeteria	Cafeteria	Gym	Gym	North Stairs	North Stairs	North Stairs	North Stairs
		Sample Date:	6/13/2010	6/13/2010	6/13/2010	6/13/2010	6/13/2010	6/13/2010	6/13/2010	6/13/2010	6/17/2010	6/17/2010
Action Level*												
PCBs (mg/kg)	Aroclor 1016	N/A	9,520 U	3.23 U	9,680 U	9,910 U	3.22 U	9,920 U	3,300 U	1.33 U	0.329 U	6,550 U
	Aroclor 1221	N/A	9,520 U	3.23 U	9,680 U	9,910 U	3.22 U	9,920 U	3,300 U	1.33 U	0.329 U	6,550 U
	Aroclor 1232	N/A	9,520 U	3.23 U	9,680 U	9,910 U	3.22 U	9,920 U	3,300 U	1.33 U	0.329 U	6,550 U
	Aroclor 1242	N/A	9,520 U	3.23 U	9,680 U	9,910 U	3.22 U	9,920 U	3,300 U	1.33 U	0.329 U	6,550 U
	Aroclor 1248	N/A	9,520 U	3.23 U	9,680 U	9,910 U	3.22 U	9,920 U	3,300 U	1.33 U	0.329 U	6,550 U
	Aroclor 1254	N/A	235,000 J	22.7 J	294,000 J	270,000 J	17.9 J	286,000 J	157,000 J	12.9 J	6.54 J	199,000 J
	Aroclor 1260	N/A	9,520 U	3.23 U	9,680 U	9,910 U	3.22 U	9,920 U	3,300 U	1.33 U	0.329 U	6,550 U
	Total PCBs	50	235,000 J	22.7 J	294,000 J	270,000 J	17.9 J	286,000 J	157,000 J	12.9 J	6.54 J	199,000 J

Notes:

mg/kg - milligrams per kilogram or parts per million (ppm).

J - Estimated value.

N/A - Not applicable.

U - Compound was not detected at specified quantitation limit.

UJ - Estimated non-detect.

Values in **Bold** indicate the compound was detected.

Values shown in Bold and shaded type exceed the listed Action Level.

PCBs - Polychlorinated Biphenyls.

* - EPA definition of PCB Caulk pertains to any caulk sample containing >= 50 mg/kg total PCBs.

Data validation for all samples completed.

TABLE 3
Summary of Analytical Results for Caulk Samples -- June and July 2010
P.S. 309K
Brooklyn, New York

Analysis	Analyte	Sample ID:	309-NS-CK- PRE-8	309-NS-CK- PRE-9	309-SW-CK- PRE-3	309-WC-CK- PRE-1	309-WC-CK- PRE-2	309-WC-CK- PRE-3	309-WC-CK- PRE-4	309-WC-CK- PRE-5	309-WC-CK- PRE-6
		Sample Description:	Door Frame Caulk	Electrical Penetration Caulk	Door Window Caulk	Door Frame Caulk	Door Frame Caulk	Marble Drinking Fountain Putty	Display Case Caulk	Green Marble Wall Joint Caulk	Former Gate Rumer Caulk
		Sample Location:	North Stairs	North Stairs	SW Corridor	1st Floor West Corridor	1st Floor West Corridor	1st Floor West Corridor	1st Floor West Corridor	1st Floor West Corridor	1st Floor West Corridor
		Sample Date:	6/17/2010	6/17/2010	7/14/2010	6/13/2010	6/13/2010	6/13/2010	6/13/2010	6/13/2010	6/13/2010
Action Level*											
PCBs (mg/kg)	Aroclor 1016	N/A	32.9 U	0.977 U	0.650 U	6,610 U	3.32 U	0.330 U	16,100 U	3.32 U	6,580 U
	Aroclor 1221	N/A	32.9 U	0.977 U	0.650 U	6,610 U	3.32 U	0.330 U	16,100 U	3.32 U	6,580 U
	Aroclor 1232	N/A	32.9 U	0.977 U	0.650 U	6,610 U	3.32 U	0.330 U	16,100 U	3.32 U	6,580 U
	Aroclor 1242	N/A	32.9 U	0.977 U	0.650 U	6,610 U	3.32 U	0.330 U	16,100 U	3.32 U	6,580 U
	Aroclor 1248	N/A	32.9 U	0.977 U	0.650 U	6,610 U	3.32 U	0.330 U	16,100 U	3.32 U	6,580 U
	Aroclor 1254	N/A	1,430 J	10.2 J	23.0 J	287,000 J	11.0 J	1.49 J	440,000 J	4.29 J	278,000 J
	Aroclor 1260	N/A	32.9 U	0.977 U	0.650 U	6,610 U	3.32 U	0.330 U	16,100 U	3.32 U	6,580 U
	Total PCBs	50	1,430 J	10.2 J	23.0 J	287,000 J	11.0 J	1.49 J	440,000 J	4.29 J	278,000 J

Notes:

mg/kg - milligrams per kilogram or parts per million (ppm).

J - Estimated value.

N/A - Not applicable.

U - Compound was not detected at specified quantitation limit.

UJ - Estimated non-detect.

Values in **Bold** indicate the compound was detected.

Values shown in **Bold and shaded type** exceed the listed
Action Level.

PCBs - Polychlorinated Biphenyls.

* - EPA definition of PCB Caulk pertains to any caulk sample
containing >= 50 mg/kg total PCBs.

Data validation for all samples completed.